



EARLY FIRE HAZARD TEST

Testing Authority: AWTA PRODUCT TESTING (NATA accredited)

Test: AS/ NZS 1530.3:1999

Test Numbers: 7-561277-CS

Test Date: 29th July 2008

Product: Sunpal multi polycarbonate

Results: Face Tested – Face

Number of specimens tested 6

Number of specimens ignited 0

	Mean	Standard	Error
Ignition Time	Nil	min	Nil
Flame Propagation Time	Nil	s	Nil
Heat Release Integral	Nil	kJ/m ²	Nil
Smoke Release, log d	-0.8533		0.0286
Optical density, d	0.1417	/ m	

Regulatory Indices:

Ignitability Index	0	Range 0-20
Spread of flame Index	0	Range 0-10
Heat Evolved Index	0	Range 0-10
Smoke Developed Index	5	Range 0-10